




SPECIFICATIONS	PART NUMBER	TYPE	FINISH	SERVICE ENTRANCE RATED
MAX VOLTAGE - 600VAC 3 Ø	KMTS-0600-XX-01-02-01-01	1	ANSI 61	YES
RATED CURRENT - 600 A	KMTS-0600-XX-02-02-01-01	3R	ANSI 61	YES
STANDARDS - UL508A	KMTS-0600-XX-03-02-01-01	4X	304 SS STD. (316 SS OPTIONAL)	YES
ENCLOSURE RATING - <b>SEE CHART</b>	KMTS-0600-XX-01-02-01-02	1	ANSI 61	NO
DURABILITY - 3050 CYCLES	KMTS-0600-XX-02-02-01-02	3R	ANSI 61	NO
LINE SIDE CABLE BEND RADIUS - 14.00"	KMTS-0600-XX-03-02-01-02	4X	304 SS STD. (316 SS OPTIONAL)	NO
LOAD SIDE CABLE BEND RADIUS - 14.00"	KMTS-0600-XX-03-02-01-02	4X	304 SS STD. (316 SS OPTIONAL)	NO

REV.	DESCRIPTION	DATE
A	INITIAL RELEASE	7/11/2020



MAILING ADDRESS: 15892 W. 74TH AVE. ARVADA, CO 80007		
NOTE: ALL DIMENSIONS IN INCHES		
PART NO. <b>KMTS-0600-XX-XX-02-01-XX</b>	DRAWN BY <b>JUSTIN HILBERT</b>	SHEET <b>1 of 2</b>
DESCRIPTION <b>600A FUSED MTS</b>		PROJECT
THIS DRAWING IS CONSIDERED COMPANY CONFIDENTIAL AND PROPERTY OF KRATOS INDUSTRIES, LLC AND SHALL NOT BE USED WITHOUT WRITTEN CONSENT.		

REV.	DESCRIPTION	DATE
A	INITIAL RELEASE	7/11/2020



MAILING ADDRESS:  
 15892 W. 74TH AVE.  
 ARVADA, CO 80007

NOTE: ALL DIMENSIONS IN INCHES



PART NO. <b>KMTS-0600-XX-XX-02-01-XX</b>	DRAWN BY <b>JUSTIN HILBERT</b>	SHEET <b>2 of 2</b>
DESCRIPTION <b>600A FUSED MTS</b>		PROJECT

THIS DRAWING IS CONSIDERED COMPANY CONFIDENTIAL AND PROPERTY OF KRATOS INDUSTRIES, LLC AND SHALL NOT BE USED WITHOUT WRITTEN CONSENT.